



FIRE DEPARTMENT
9 METROTECH CENTER BROOKLYN, N.Y. 11201-3857

CERTIFICATE OF APPROVAL # 4905
THIS CERTIFICATE IS REVOCABLE, NOT TRANSFERABLE
AND EXPIRES ON July 31, 2007

May 4, 2005

Ms. Sandra B. Debrot
Vice President
Fibrelite Corporation
80 Broadway
Cresskill, NJ 07626

F.P. Index#: 0502009A

By order of Fire Commissioner, Nicholas Scoppetta and pursuant to §27-4015 of the Administrative Code, the following equipment or system is accepted for use provided the conditions as outlined below are in full compliance.

Applicant: Fibrelite Corporation

Product: Catchment basin with automatic drain valve for underground motor fuel tanks

Model No:

1. 1227 standard burial containment
2. 1228 shallow burial containment
3. 1229-76 extreme shallow burial containment

Pertinent Code Section: 3RCNY§21-20 and C-27-4065-f. of NY City Fire Prevention Code
40 CRF 280.20 & 280.30

Laboratory: International Testing Laboratories

Testing Standard: ULC/ORD-C58.19-1992

Test Report: Lab No: 612085 Issued: January 3, 2002
Issued to Fairfield Multiple Listing

Conditions of Approval:


1. The rubber gaskets material used on these spill containment device shall be the same as submitted to International Testing laboratories for testing report #612085 and shall not be changed in any way without prior written approval of the Fire Department.

COA # 4905 for Fibrelite Corporation's catchment basin for underground motor fuel tanks
May 4, 2005
Page 2 of 2.

2. Installation shall comply with all applicable New York City Codes, Rules, Regulations, etc. including, but not limited to, 3RCNY § 21-20 effective March 21, 2000.
Note: To obtain a copy of the New York City Administrative Fire Code you may contact Citybooks Store at 212-669-8246. For a copy of the Fire Department Rules of the City of New York please contact Command Information Services 518-436-8647.
3. Manufacturer's installation and maintenance procedures and limitations shall be complied with. The use of the above spill containment device shall be limited to the indicated intent and has not been acceptable for other uses or applications. Manufacturer shall retain follow up service requirements of International Testing Laboratories.
4. Equipment shall have secured and shall maintain all required approvals and shall meet all applicable Federal and State requirements.
5. Certificate of Approval number shall be plainly and permanently stamped or otherwise fixed upon each device by the manufacturer.
6. The Certificate of approval is issued upon condition that the material or equipment's technology does not violate any patent, trade name, trade secret or other intellectual right.
7. The Fire Department Certificate of Approval does not constitute an endorsement or recommendation of your product by the Fire Department, but is a certification that your product, as represented, meets the standards as of the date of issuance.
8. The Fire Department's conditions of approval shall be enumerated in the installation manuals and sales brochures that will be provided to NYC buyers, users and installers.
9. The Fire Department reserves the right to withdraw this approval at any time in the event there is a reasonable doubt that the product does not operate or perform as required by code, the conditions of this resolution or as represented in your application.
10. As the manufacturer of this equipment/material, you should be aware that any end users who fails to comply with the condition as outlined in the approval will be subject to enforcement action which may include fines and imprisonment.

Any change in company name or ownership, product name, material of construction, product design, or model number of any product included on this certificate must be immediately reported to this Department in writing.

Very truly yours,



Anthony Houch
Senior Project Manager
Technology Management