



FIRE DEPARTMENT
9 METROTECH CENTER BROOKLYN, N.Y. 11201-3857

CERTIFICATE OF APPROVAL # 5052
THIS CERTIFICATE IS REVOCABLE, NOT TRANSFERABLE
AND EXPIRES ON July 26, 2007

July 27, 2004

Mr. Jude M. Anna
Approval Agency Coordinator
Veeder-Root
6th Ave at Burns Crossing
Altoona, PA 16601

By order of Fire Commissioner Nicholas Scoppetta, and pursuant to §27-4015 of the Administrative Code, the following equipment or system is accepted for use provided the conditions as outlined below are in full compliance.

Manufacturer: VEEDER-ROOT

Product: The REDJACKET Submersible liquid petroleum motor fuels pumps.

Models and limitation

- (1) P75U1RJ, P150U1RJ, P200U13RJ and X3P150U1RJ series with an aluminum shell limited for gasoline, diesel and oxygenated motor fuel service including up to 20% methanol, 20% ethanol and up to 20% MTBE, ETBE and TAME as listed in the UL Test Report mentioned below;
- (2) AGP75S1RJ, AGP150S1RJ, AGP200S1-3RJ and X3AGP150S1RJ series with stainless steel for gasoline including up to 100% methanol, 100% ethanol and up to 20% MTBE, ETBE and TAME as listed in the UL Test Report mentioned below.

Pertinent Code Section: C-27-4081-b-4, and 27-4082-b-2-A. of NYC Fire Prevention Code and Section (m) of 3RCNY §21-20.

Laboratory: Underwriters Laboratories Inc.

Test Report: File MH6497 Vol. 4 Sec. 5 Issued on 3-3-2004

Conditions of Approval:

1. Motor wiring shall be in accordance with the New York City Electrical code for hazardous locations.
2. The installation and use of pumps shall comply with applicable New York City Code, rules and regulations including 3RCNY § 21-20 and/or 3RCNY § 21-21. Manufacturer's and Underwriters Laboratories Inc.'s safety requirements and limitations shall be complied with.
Note: For a copy of the Fire Department Rules of the City of New York please contact Command Information Services, Legal Publishing Division at 518-436-8647.
3. Pumps shall be Underwriters Laboratories Inc. listed and pump manufacturer shall retain follow up service requirements of Underwriters Laboratories Inc.
4. Equipment shall have secured and shall maintain all required approvals and shall meet all applicable Federal and State requirements. The use of this product shall be limited to the indicated intent and has not been acceptable for other uses or applications.
5. Certificate of Approval number shall be plainly and permanently stamped or otherwise fixed upon each pump by the manufacturer
6. The Certificate of Approval is issued upon condition that the material or equipment's technology does not violate any patent, trade name, trade secret or other intellectual right.
7. A site demonstration of your equipment, if requested by this Bureau, shall be performed by a representative of your company in order to train Fire Department field inspectors on the proper operation of this equipment.
8. The Fire Department's conditions of approval shall be enumerated in the installation manuals and brochures that will be provided to New York City buyers, users and installers
9. The Fire Department Certificate of Approval does not constitute an endorsement or recommendation of your product by the Fire Department, but is a certification that your product, as represented, meets the standards as of the date of issuance
10. The Fire Department reserves the right to withdraw this approval at any time in the event there is a reasonable doubt that the product does not operate or perform as required by code, the conditions of this resolution or as represented in your application.
11. As the manufacturer of this equipment/material, you should be aware that any end users who fails to comply with the condition as outlined in the approval will be subject to enforcement action which may include fines and imprisonment.

VEEDER-ROOT / REDJACKET submersible pump
Certificate of Approval # 5052
July 27, 2004
Page 3 of 3.

Any change in company name or ownership, product name, product design, material of construction or model number of any product included on this certificate must be immediately reported to this Department in writing.

Very truly yours,

A handwritten signature in black ink, appearing to read "Anthony Hsueh". The signature is fluid and cursive, with a long horizontal stroke at the end.

Anthony Hsueh
Associate Project Manager

AH / 50520607.doc